



March 4, 2015

PROCON
PREMIER CONCRETE, INC
MIKE DONOHUE
8431 HIGHWAY 57
BAILEYS HARBOR WI 54202

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: PROCON
Product Name: HOLDING OR PUMP
Model Number(s): 3003
(64.63 IN. L.L., 46.5 GAL/IN., 84 IN. MAX. DEPTH OF BURY;
TANK DIMENSIONS (OD) = 156 IN. L X 81 IN. W X 77.5 IN. H)
Product File No: 20150011

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2020.**

This approval supersedes the approval issued on 4/28/2010 under product file number 20100141.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Pipe materials constructed in conformance with Table SPS 384.30-2 or 384.30-11, Wis. Admin. Code poured into access cover.
 - Four inch inlet in tank cover for holding tanks only.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Bedding: Place tanks a min. 4 in. of tampered bedding material of which 100% shall pass through $\frac{3}{4}$ in. screen. Sand, pea gravel, road gravel or $\frac{3}{4}$ in. screened stone is acceptable. In wet excavations, use min. 6 in. tampered bedding. Bedding shall be raked to allow $\frac{1}{2}$ in. center depression. Extend bedding min. 6 in. on all sides of tank bottom.
- Backfill: Tank backfill shall consist of sand, gravel and/or soil materials that are dry of which 100% shall pass a 2 in. screen. No parallel backfilling or compaction is permitted. When backfilling, equipment shall stay far enough away from the tank to prevent stress to the tank. Finish grade contours over the tank shall be done in such a manner as to eliminate surface drainage ponding over tank.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.; POWTS Product Reviewer
phone: (608) 267-5265, fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:
www.surveymonkey.com/s/dspscustomersatisfaction